

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Test Report

No.14-002016-PR04

(PB-A01-02-en-01)

Client	ALUMIL S.A. Industrial Area 61100 Kilkis Greece
Product	Double combined side hung & turn tilt window with opening meeting stile
Designation	System designation: M9660
Performance-relevant product details	Material: Aluminium Profiles with thermal break
Overall dimensions (W x H)	1,290 mm x 2,210 mm
Special features	—/—

Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2000-06

EN 1027:2000-06

EN 12211:2000-06

Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class E750

Resistance to wind load

according to EN 12210:1999-11/AC:2002-08



Class C2 / B2

ift Rosenheim

28.08.2014

Andreas Graf, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Construction Product Testing

Florian Meyer, Dipl.-Ing. (FH)
Operating Testing Officer
Construction Product Testing

Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 24 pages.